SPERRY-PILTZ UTILITY ICE DAMAGE INDEX

Ice Index	Radial Ice Amount (inches)	Wind (mph)	Damage and Impact Descriptions
1	< 0.25	15-25	Some localized utility interruptions possible, typically lasting only 1 or 2 hours maximum.
	0.25-0.50	< 15	
2	< 0.25	>= 25	Scattered utility interruptions expected, typically lasting less than 8-12 hours maximum.
	0.25-0.50	15-25	
	0.50-1.00	< 15	
3	0.25-0.50	>= 25	Numerous utility interruptions, with some damage to main feeder lines expected with outages lasting from 1-3 days.
	0.50-0.75	15-25	
	0.75-1.00	< 15	
4	0.50-0.75	>= 25	Prolonged & widespread utility interruptions, with extensive damage to main distribution feeder lines and possibly some high voltage transmission lines. Outages expected to last more than 3 to 5 days.
	0.75-1.00	15-25	
	1.00-1.50	< 15	
5	0.75-1.00	>= 25	Catastrophic damage to entire utility systems. Outages could last from one week to several weeks in some areas.
	1.00-1.50	15-25	
	> 1.50	< 15	